

Material Test Report



Ground Science South West

Geotechnical & Environmental Consultants

Report Number: GSSW576-17
Issue Number: 1
Date Issued: 05/08/2020
Client: AEROLITE QUARRIES PTY LTD
 325 Old Boundary Road , ANAKIE VIC 3115
Contact: HAYDEN EDGAR
Project Number: GSSW576
Project Name: PRODUCT SUITABILITY TESTING
Project Location: ANAKIE
Work Request: 7499
Sample Number: 576-S27
Date Sampled: 30/07/2020
Dates Tested: 31/07/2020 - 05/08/2020
Sampling Method: Sampled by Client - Tested as Received
The results apply to the sample as received
Material: Soil
Material Source: Aerolite Quarries Anakie

Ground Science South West Pty Ltd
 10 Dowsett Street South Geelong Vic 3220
 Phone: (03) 5282 1566
 Email: chrism@groundscience.com.au

Accredited for compliance with ISO/IEC 17025 - Testing



Approved Signatory: Chris Mamalis
 Laboratory Manager
 NATA Accredited Laboratory Number: 20109

Particle Size Distribution (AS1289 3.6.1)				
Sieve	Passed %	Passing Limits	Retained %	Retained Limits
6.7 mm	100		0	
4.75 mm	100		0	
2.36 mm	97		3	
1.18 mm	80		17	
0.6 mm	61		18	
0.425 mm	50		11	
0.3 mm	40		11	
0.15 mm	23		16	
0.075 mm	15		8	

